

ADDENDUM NO. 1

TO THE CONTRACT DOCUMENTS AND SPECIFICATIONS FOR
VILLAGE OF ROSCOE
2021 RESIDENTIAL STREET PROGRAM

Bid Date: July 1, 2021, at 10:00 am

SPECIFICATIONS

Special Provisions

The Special Provision for EARTH EXCAVATION has been revised and should read as follows.

“EARTH EXCAVATION

This work shall be in accordance with Section 202 of the Standard Specifications for Road and Bridge Construction. Within the limits of the River Street Project, the entire roadway will be excavated, and the proposed roadway will be constructed to a pavement structure with 12” of aggregate base course and 3” of Hot-mix Asphalt Surface Course that shall be in accordance with Section 351 and 406, respectively, of the Standard Specifications for Road and Bridge. No rock is anticipated throughout this section of roadway. The Village of Roscoe will keep all excavated spoils and they shall be transported to Chicory Ridge Park by the Contractor. Coordination with the Engineer for final location is required. The work described in this provision shall be paid at a unit price per CUBIC YARD for EARTH EXCAVATION.”

This Addendum consists of one (1) page.

Addendum No. 1 has been prepared by:



Brandon Boggs
Engineer

END OF ADDENDUM NO. 1